

Hylomar Limited
Hylo House
Cale Lane, New Springs
Wigan WN2 1 JT
ENGLAND

Rotthauer Str. 19
45879 Gelsenkirchen

Telephone +49 (0)209 9242-0
Extension +49 (0)209 9242-270
Telefax +49 (0)209 9242-212
E-Mail k.stefanski@hyg.de
Internet www.hyg.de

Reference: K-193629-10-Sf/st
Contact person: Mrs. Stefanski

Gelsenkirchen, 23.08.2010

TEST CERTIFICATE on basis of the KTW-Guideline

Product: Hylomar M (blue)
Test specimen: glass plates, coated with Hylomar M (blue)
Kind of test: Product test / Permission test Supervision test


The a.m. material meets the requirements according to the test reports dated **23.08.2010**, Ref.-No.: **K-1193629-10-Sf/st** for the following applications and temperatures:

Applications:	cold water (23°C)	warm water (60°C)	hot water (85°C)
Pipes ID < 80 mm (domestic distribution)	---	---	---
Pipes 80 mm ≤ ID < 300 mm (supply pipelines)	---	---	---
Pipes ID ≥ 300 mm (mains)	---	---	---
Simple fittings, assembled product housings for pipes ID < 80 mm	---	---	---
Simple fittings, assembled product housings for pipes 80 mm ≤ ID < 300 mm	---	---	---
Simple fittings, assembled product housings for pipes ID ≥ 300 mm	---	---	---
Seals for pipes ID < 80 mm	passed	---	---
Seals for pipes 80 mm ≤ ID < 300 mm	passed	---	---
Seals for pipes ID ≥ 300 mm	passed	---	---
Storage systems within the domestic distribution system including repair products	---	---	---
Storage systems outside the domestic distribution system including repair products	---	---	---

as far as technically suited.

This test certificate is valid beginning with the date of issue and is ending by **23.08.2015** as far as there are no changes in the formula. After this time it can be extended for further 5 years if demanded.

The Director of the Institute
on behalf of


(Food Chemist C. Karau)
substitutional Head of the Dept. for
water hygienic material testings



The results and conclusions exclusively refer to the investigated samples and the relevant laws.
The validity of this document expires in case of modifications in the composition of the product or the processing conditions.

This document must not be reproduced except in full, without our written approval.



DAP-PL-2548.00